



NOTES:

1. MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL HAVE BOLT-DOWN LIDS WITH NEOPRENE SEALS.
2. MANHOLES SHALL HAVE A MINIMUM DROP OF 0.10 FEET FROM INFLUENT INVERT TO EFFLUENT INVERT.

PEACHTREE CITY WATER & SEWERAGE AUTHORITY STANDARD DETAIL

STANDARD PRECAST MANHOLE

REVISED: 08/31/2015

SCALE: N.T.S.

DETAIL NO.

101