



NOTES:

1. OUTSIDE DROPS REQUIRED WHEN INSIDE DROP IS GREATER THAN 2 FEET.
2. MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL HAVE BOLT-DOWN LIDS WITH NEOPRENE SEALS.
3. PIPE ENCASED IN CONCRETE SHALL BE WRAPPED WITH MINIMUM 10 MIL PLASTIC.

PEACHTREE CITY WATER & SEWERAGE AUTHORITY STANDARD DETAIL

DROP MANHOLE

REVISED: 08/31/2015
SCALE: N.T.S.
DETAIL NO.
102