



NOTES:

1. DISCHARGE MANHOLE AND ALL MANHOLES WITHIN 1,600 FEET OF THE DISCHARGE MANHOLE SHALL BE LINED WITH A CORROSION RESISTANT FLEXIBLE ELASTOMERIC POLYURETHANE OR EPOXY LINING SYSTEM.

PEACHTREE CITY WATER & SEWERAGE AUTHORITY STANDARD DETAIL

SANITARY FORCE MAIN DISCHARGE MANHOLE

REVISED: 08/31/2015

SCALE: N.T.S.

DETAIL NO.

105