



NOTES:

1. CLEANOUT SHALL BE LOCATED 2-FEET INSIDE PROPERTY LINE.
2. CLEANOUT RISER SHALL EXTEND A MINIMUM OF 4-FEET ABOVE FINISHED GRADE UNTIL SERVICE LINE IS TIED IN AND FINAL GRADING IS COMPLETE. AT THAT TIME, IT SHALL BE CUT AND CAPPED (WITH A THREADED CAP) AT FINISHED GRADE.

PEACHTREE CITY WATER & SEWERAGE AUTHORITY STANDARD DETAIL

SEWER SERVICE LATERAL AND CLEANOUT DETAIL

REVISED: 08/31/2015

SCALE: N.T.S.

DETAIL NO.

107