



**NOTES:**

1. PIPE USED FOR CREEK CROSSINGS SHALL BE DUCTILE IRON PIPE. JOINTS SHALL BE RESTRAINED FOR A MINIMUM OF 20 FEET BEYOND TOP OF BANK ON EACH SIDE OF CREEK.
2. MINIMUM DEPTH OF COVER ABOVE CASING PIPE SHALL BE 12-INCHES.
3. REFER TO DETAIL 108 FOR CASING DIAMETER AND DETAILS.
4. PLACE STONE RIP-RAP APPROXIMATELY 5 FEET UPSTREAM AND 5 FEET DOWNSTREAM FROM CENTERLINE OF PIPE ALONG CREEK BED.

PEACHTREE CITY WATER & SEWERAGE AUTHORITY STANDARD DETAIL

**CREEK CROSSING**

REVISED: 08/31/2015

SCALE: N.T.S.

DETAIL NO.

**109**